

STATE SERVICE OF UKRAINE ON FOOD SAFETY AND CONSUMER PROTECTION

Hrinchenko B. st.1, Kyiv, 01001, tel.279-12-70, 279-75-58, fax 279-48-83,

email: info@consumer.gov.ua

Approved
Head of SSUFSCP
Lapa V.

CONCLUSION
of the sanitary and epidemiological examination

of 05.09.2019

№12.2-18-/19723

Examination object: Facade system: flexible clinker "IN-CLINKER"; facade system: flexible brick "IN-BRICK"; facade system: flexible ceramics "IN-KERAM"

produced in accordance with: TC U 23.9-42966730-001:2019 "Facade systems on a flexible basis. Technical conditions"

Code by SCGS UCTZED, item: 23.91.12

Area of implementation and realization of the examination object: Building, wholesale and retail trade.

Country-producer: LLC "IN DEMAND", Ukraine, 02002, Kyiv, Ovanes Tumanyan st., 15A, off.634. EDRPOU code 42966730, manufacture address: 37710, Ukraine, Poltava reg., Orzhytskyi dist., Lazirky vill., Tsentralna st., 2B/2

Examination applicant: LLC "IN DEMAND", Ukraine, 02002, Kyiv, Ovanes Tumanyan st., 15A, off.634. EDRPOU code 42966730

Data about the contract of supplying the object to Ukraine: Domestic production

Examination object corresponds to the established medical safety criteria/indicators:

Level of migration of chemical substances into atmospheric air (limit allowable concentration, average daily, not more, mg/m³): formaldehyde - 0,003; acetaldehyde - 0,01; acetone - 0,35; toluene - 0,6; methyl alcohol - 0,5; butyl alcohol - 0,1; acrylonitrile - 0.03; odor level does not exceed 2 points according to State Sanitary Regulations and Standards 8.2.1-181-2012 "Polymer and polymer-containing materials, products and constructions that are used in building and furniture production. Hygienic requirements and Instructions 603.A-91" "Instruction for sanitary and hygienic assessment of polymer materials, designed for implementation in building and furniture production". Effective specific activity of natural radionuclides - not more than 370 Bq/kg according to NRSU-97 "Radiation safety standards of Ukraine. State hygienic standards".

